



WINCHESTER FIRE AND RESCUE DEPARTMENT

OFFICE OF THE FIRE MARSHAL

231 E. Piccadilly St., Suite 330
Winchester, VA 22601
(540) 662-2298



FIREFIGHTER SAFETY BULLETIN



On July 20, 2012, the Fire Marshal's Office was notified by the Winchester Police Department of potential fire code violations at 807-A N. Loudoun Street. The business that occupies this tenant space is Yun's Cleaners. During our inspection we found the business to have excessive combustible storage, blocked electric panel, non-functioning egress lighting, and potential heat sources in contact with combustibles.

At this time the business has been issued a notice of violation and the owners have been very good to work with. They are in the process of making the necessary corrections and our office is working with them to ensure that they are in compliance with the fire code and have a safe establishment for their customers as well as their employees.

This information is provided to make the operational members of the department aware of the potential hazards and risks associated with emergency response to various locations within the city limits to prevent injury and improve emergency operations should the need for fire and rescue assistance arise. This information shall be used for fire and rescue purposes only.

Questions concerning this bulletin may be directed to the Fire Marshal's Office.